



ವೈದ್ಯಾಧಿಕಾರಿಗಳ ಕಛೇರಿ, ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ, ಬೆಳ್ಳಾವಿ, ತುಮಕೂರು ತಾಲ್ಲೂಕು

Ref.No : 95/ಪ್ರಾ/ಆರೋಗ್ಯ: 109/06-3-2024


Dated: 06/3/2024


### Safe Drinking and Sanitary Condition Certificate

It is certified that an inspection team headed by **Dr. Radhakrishna.M.C** from Medical Officer Primary Health Center, Bellavi, inspected the **Kids International School**, Bellavi, Tumkur Tq on 04-02-2024 and on the basis of Water Test Report dated 27-02-2024 of **Siddaganga Institute of Technology Laboratory**, Tumkur -572103 certified that the **Kids International School**, Bellavi, Tumkur Tq has safe drinking water facilities for the students and staff of the institution. School is also maintains the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T. Govt.

**This certificate is valid till 05-03-2025.**

To  
Kids International School  
Bellavi  
Tumkur -572107

  
VIGYALAYA HUMANISTIC  
EDUCATIONAL AWARENESS - 2021  
Channanahally Cross.  
Bellavi, Tumkur Taluk

Signature  
  
(Radhakrishna.M.C)  
Medical Officer  
PHO Primary Health Center,  
Bellavi, Tumkur-572107  
ಡಾ. ರಾಧಕೃಷ್ಣ ಎಂ.ಸಿ.  
ಆಡಳಿತ ವೈದ್ಯಾಧಿಕಾರಿಗಳು  
ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ  
ಬೆಳ್ಳಾವಿ, ತುಮಕೂರು ತಾಲ್ಲೂಕು.

For KIDS INTERNATIONAL SCHOOL  
  
Secretary

**SIDDAGANGA INSTITUTE OF TECHNOLOGY**

**TUMAKURU – 572 103**



**TEST REPORT**

Ref. No. : Nil  
Name of the Work : Testing of water sample for Drinking Purpose  
Name of the Agency : Kids International School, Bellavi, Tumkur  
Consultant : Dr. Vijay V Nair

Department of Civil Engineering  
Date: 27-02-2024

*Upran 27/02/2024*

Principal  
Siddaganga Institute of Technology  
Tumakuru – 572 103


- NB: 1. This report consists of TWO pages and ONE Table**  
**2. This report should not be published either in part or full except with permission in writing from the Principal of the Institute.**

*[Signature]*  
VIDYALAYA HUMANISTIC  
EDUCATIONAL AWARENESS TRUST  
Channarayana Cross,  
Bellavi, Tumkur Taluk


For KIDS INTERNATIONAL SCHOOL  
*[Signature]*  
Secretary


### Bore Well Water Sample

| Sl.No | Parameter                                    | Results Obtained | Requirement (Acceptable limit) (mg/l) | Permissible Limit As per standards – IS 10500-2012 (In the absences of alternate source) (mg/l) | Remarks                      |
|-------|--|------------------|---------------------------------------|---|------------------------------|
| 1     | Acidity (in mg/l) as CaCO <sub>3</sub>       | 22               | -                                     | -   | No Prescribed Limit          |
| 2     | Total Alkalinity (mg/l) as CaCO <sub>3</sub> | 326              | 200                                   | 600   | Higher than Acceptable Limit |
| 3     | pH   | 6.62             | 6.5-8.5                               | 6.5-8.5   | OK                           |
| 4     | Total Hardness (mg/l) as CaCO <sub>3</sub>   | 294              | 200                                   | 600   | Higher than Acceptable Limit |
| 5     | Chlorides (mg/l)                             | 83               | 250                                   | 1000  | OK                           |
| 6     | Fluorides (mg/l)                             | 0.58             | 1.0                                   | 1.5   | OK                           |
| 7     | Sulphates (mg/l)                             | 31               | 200                                   | 400   | OK                           |
| 8     | Nitrates (mg/l)                              | 0.4              | 45                                    | 45  | OK                           |
| 9     | Calcium (Ca) in (mg/l)                       | 71               | 75                                    | 200   | OK                           |
| 10    | Total Dissolved Solids (ppm)                 | 562              | 500                                   | 2000  | Higher than Acceptable Limit |
| 11    | Electric Conductivity (μS/cm)                | 151              | 400                                   | No to exceed as per WHO standards   | OK                           |


  
 - 27/2/24.  
**Staff Incharge**  
**(Dr. Vijay V Nair)**

Thanking you,

  
 27/2/24.  
**(Dr. Pavan Kumar Emani)**  
**Professor and Head**  
**Dept. of Civil Engg.**

  
**VIDYAKAYA HUMANISTIC**  
**FOR EDUCATIONAL ACHIEVEMENTS**  
**Channarayana Cross,**  
**Belavi, Tumkur Taluk**

For KIDS INTERNATIONAL SCHOOL

  
**Secretary**